



# Life Science Laboratories, Inc.

Date Printed:

1/4/21

## Laboratory Analysis Report Prepared For Skaneateles Central Schools

Client Project ID: Lead Testing 2020

LSL Project ID: 2019866

Elaine MacLachlin  
Skaneateles Central Schools  
49 East Elizabeth Street  
Skaneateles, NY 13152

Phone: (315) 291-2297

*A copy of this report was sent to:*

Sample ID: Lead Samples

LSL Sample ID: 2019866-001

Location:

Receive Date/Time: 12/03/20 13:10

Sampled: 12/02/20 6:54

Project Rec'd by: tjn1

Sampled By: JB

Matrix: PWS

Analytical Method	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
Analyte	Result Units			

(1) Lead Study

Number of Samples

39

MT

*Please refer to the chain of custody form on the last page of this report for the detailed descriptions of where these samples were taken.*

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain data qualifiers and specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab  
5854 Butternut Drive  
East Syracuse, NY 13057  
Tel. (315) 445-1900  
Fax (315) 445-1104  
NYS DOH ELAP #10248

LSL North Lab  
131 St. Lawrence Avenue  
Waddington, NY 13694  
Tel. (315) 388-4476  
Fax (315) 388-4061  
NYS DOH ELAP #10900

LSL Finger Lakes Lab  
16 N. Main St., PO Box 424  
Wayland, NY 14572  
Tel. (585) 213-4090  
Fax (585) 213-4192  
NYS DOH ELAP #11667

LSL Southern Tier Office  
Cuba, NY  
Tel. (585) 209-4032

LSL MidLakes Office  
Canandaigua, NY  
Tel. (585) 728-3320

Reviewed by:

*Kristin E. Carpenter*  
Kristin E. Carpenter, Quality Staff

Date:

*01/08/21*

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-1

**Lab ID:** 2019866-001A  
**Collection Date:** 12/02/20 6:54  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0083	mg/L	12/29/20 17:06

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-2

**Lab ID:** 2019866-002A  
**Collection Date:** 12/02/20 6:55  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0056	mg/L	12/29/20 17:16

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-3

**Lab ID:** 2019866-003A  
**Collection Date:** 12/02/20 6:55  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0046	mg/L	12/29/20 17:19

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

Client Sample ID: *SCSD-4*

**Lab ID:** 2019866-004A  
**Collection Date:** 12/02/20 6:58  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0021	mg/L	12/29/20 17:23

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-5

**Lab ID:** 2019866-005A  
**Collection Date:** 12/02/20 6:58  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0023	mg/L	12/29/20 17:26

**Qualifiers:** \* Value may exceed the Acceptable Level  
 E Value exceeds the instrument calibration range  
 J Analyte detected below the PQL  
 P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Practical Quantitation Limit (PQL)  
 S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-6

**Lab ID:** 2019866-006A  
**Collection Date:** 12/02/20 6:59  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.011	mg/L	12/29/20 17:29

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-7

**Lab ID:** 2019866-007A  
**Collection Date:** 12/02/20 7:00  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.032 *	mg/L	12/29/20 17:33

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-8

**Lab ID:** 2019866-008A  
**Collection Date:** 12/02/20 7:01  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0055	mg/L	12/29/20 17:43

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-9

**Lab ID:** 2019866-009A  
**Collection Date:** 12/02/20 7:02  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.010	mg/L	12/29/20 17:46

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

Client Sample ID: *SCSD-10*

**Lab ID:** 2019866-010A  
**Collection Date:** 12/02/20 7:02  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	12/29/20 17:50

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-11

**Lab ID:** 2019866-011A  
**Collection Date:** 12/02/20 7:04  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	12/29/20 17:53

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-12

**Lab ID:** 2019866-012A  
**Collection Date:** 12/02/20 7:04  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0014	mg/L	12/29/20 17:56

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-13  
**Lab ID:** 2019866-013A  
**Collection Date:** 12/02/20 7:05  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8, Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0020	mg/L	12/29/20 18:00

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-14

**Lab ID:** 2019866-014A  
**Collection Date:** 12/02/20 7:08  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	12/29/20 18:03

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-15

**Lab ID:** 2019866-015A  
**Collection Date:** 12/02/20 7:10  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	12/29/20 18:06

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

Client Sample ID: *SCSD-16*

**Lab ID:** 2019866-016A  
**Collection Date:** 12/02/20 7:10  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	12/29/20 18:10

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

Client Sample ID: *SCSD-17*

**Lab ID:** 2019866-017A  
**Collection Date:** 12/02/20 7:10  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0087	mg/L	12/29/20 18:13

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-18

**Lab ID:** 2019866-018A  
**Collection Date:** 12/02/20 7:13  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0098	mg/L	12/29/20 18:23

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

Client Sample ID: *SCSD-19*

**Lab ID:** 2019866-019A  
**Collection Date:** 12/02/20 7:13  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0042	mg/L	12/29/20 18:26

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

Client Sample ID: *SCSD-20*

**Lab ID:** 2019866-020A  
**Collection Date:** 12/02/20 7:15  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0073	mg/L	12/29/20 18:30

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-21

**Lab ID:** 2019866-021A  
**Collection Date:** 12/02/20 7:15  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8, Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0051	mg/L	12/29/20 18:33

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

Client Sample ID: *SCSD-22*

**Lab ID:** 2019866-022A  
**Collection Date:** 12/02/20 7:16  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0022	mg/L	12/29/20 18:43

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-23

**Lab ID:** 2019866-023A  
**Collection Date:** 12/02/20 7:16  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0024	mg/L	12/29/20 18:47

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-24

**Lab ID:** 2019866-024A  
**Collection Date:** 12/02/20 7:17  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0072	mg/L	12/29/20 18:50

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-25

**Lab ID:** 2019866-025A  
**Collection Date:** 12/02/20 7:17  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0028	mg/L	12/29/20 19:00

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-26

**Lab ID:** 2019866-026A  
**Collection Date:** 12/02/20 7:19  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	12/29/20 19:03

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-27

**Lab ID:** 2019866-027A  
**Collection Date:** 12/02/20 7:19  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.011	mg/L	12/29/20 19:07

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-28  
**Lab ID:** 2019866-028A  
**Collection Date:** 12/02/20 7:20  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0018	mg/L	12/29/20 19:10

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-29

**Lab ID:** 2019866-029A  
**Collection Date:** 12/02/20 7:21  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0073	mg/L	12/29/20 19:13

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-30

**Lab ID:** 2019866-030A  
**Collection Date:** 12/02/20 7:21  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0047	mg/L	12/29/20 19:17

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-31  
**Lab ID:** 2019866-031A  
**Collection Date:** 12/02/20 7:23  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8, Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.040 *	mg/L	12/29/20 19:20

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-32

**Lab ID:** 2019866-032A  
**Collection Date:** 12/02/20 7:23  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0020	mg/L	12/29/20 19:23

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-33

**Lab ID:** 2019866-033A  
**Collection Date:** 12/02/20 7:23  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0019	mg/L	12/29/20 19:27

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-34

**Lab ID:** 2019866-034A  
**Collection Date:** 12/02/20 7:23  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	12/29/20 19:30

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-35

**Lab ID:** 2019866-035A  
**Collection Date:** 12/02/20 7:25  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.015 *	mg/L	12/29/20 19:40

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-36

**Lab ID:** 2019866-036A  
**Collection Date:** 12/02/20 7:25  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.011	mg/L	12/29/20 19:44

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-37

**Lab ID:** 2019866-037A  
**Collection Date:** 12/02/20 7:29  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	12/29/20 19:47

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-38

**Lab ID:** 2019866-038A  
**Collection Date:** 12/02/20 7:30  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.011	mg/L	12/29/20 19:50

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Skaneateles Central Schools  
**Location:** Lead Testing 2020  
**Matrix:** PWS

**Client Sample ID:** SCSD-39

**Lab ID:** 2019866-039A  
**Collection Date:** 12/02/20 7:32  
**Date Received:** 12/03/20 13:10

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0056	mg/L	12/29/20 19:54

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits





Life Science Laboratories, Inc.

5854 Butternut Drive  
East Syracuse, NY 13057

Phone # (315) 445-1900

Telefax # (315) 445-1104

Chain of Custody Record

Client: Skaneateles CSD Phone # (315) 685-8361  
Address: 45 E. Elizabeth St. Fax # (315) 685-0347  
Skaneateles, NY 13152

Contact Person: Elaine MacLachlan  
LSL Project #: Lead testing 2020  
Client's Site I.D.:  
Samples Preserved  
Upon Receipt at Lab  
Client's Project I.D.:  
set above

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
	1-KIT-1	12/2/20	6:54	X		PW	None	1	250 mL	SCSD-1	Lead	
	2-KIT-2		6:55	X				1		2		
	3-KIT-3		6:55	X				1		3		
	4-WM-36		6:58	X				1		4		
	5-WM-37		6:58	X				1		5		
	6-WM-38		6:59	X				1		6		
	7-WM-35		7:00	X				1		7		
	8-WM C30A		7:01	X				1		8		
	9-WM-34		7:02	X				1		9		
	10-WM BF 45		7:02	X				1		10		
	11-WM BF C30		7:04	X				1		11		
	12-WM-31		7:04	X				1		12		
	13-L.A. KIT		7:05	X				1		13		
	14-WM-20B BF		7:05	X				1		14		

Notes and Hazard Identifications:

\* TAKEN FROM SAMPLE BOTTLE

Samples Preserved Upon Receipt at Lab

Custody Transfers		Date	Time
Sampled and Relinquished By:			
Print Name:	Signature:		
Received By:			
Relinquished By: <u>[Signature]</u>	Received By:	12/3/20	1310
Relinquished By:	Received for Lab By: <u>[Signature]</u>	12/03/20	1310

Shipment Method:

Samples Received Intact:

16.1°C



Life Science Laboratories, Inc.

5854 Butternut Drive  
East Syracuse, NY 13057

Phone # (315) 445-1900

Telefax # (315) 445-1104

Chain of Custody Record

Client: Skaneateles CSD Phone # (315) 685-8361  
Address: 45 E. Elizabeth St. Fax # (315) 685-0347  
Skaneateles, NY 13152

Contact Person: Elaire MacLachlan  
LSL Project #: Lead testing  
Client's Site I.D.:

Authorization: (315) 291-2297 Office  
Client's Project I.D.: 06 meet sample ID

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
	15-N21	12/2/24	7:10	X		PW	None	1	250 mL	SCCD-15 Lead		
	16-N21A		7:10	X				1		16		
	17-N21B		7:10	X				1		17		
	18 WM 2 A		7:13	X				1		18		
	19 WM 2 B		7:13	X				1		19		
	20 WM 3 A		7:15	X				1		20		
	21 WM 3 B		7:15	X				1		21		
	22 WM 1 A		7:16	X				1		22		
	23 WM 1 B		7:16	X				1		23		
	24 WM 4 A		7:17	X				1		24		
	25 WM 4 B		7:17	X				1		25		
	26 WM 5 BF		7:19	X				1		26		
	27 WM 5		7:19	X				1		27		
	28 WM 6	✓	7:20	X				1		28		

Notes and Hazard identifications:  
  
Samples Preserved  
Upon Receipt at Lab

Custody Transfers		Date	Time
Sampled and Relinquished By:			
Print Name:	Signature:		
Received By:			
Relinquished By: <u>John Butler</u>	Received By:	12/3/24	1310
Relinquished By:	Received for Lab By: <u>[Signature]</u>	12/03/24	1310

Shipment Method: \_\_\_\_\_ Samples Received Intact:



Life Science Laboratories, Inc.

5854 Butternut Drive  
East Syracuse, NY 13057

Phone # (315) 445-1900

Telefax # (315) 445-1104

2019866

SkanCS

2174

### Chain of Custody Record

<b>Client:</b> <u>Skaneateles CSD</u>	<b>Phone #:</b> <u>(315) 685-8361</u>	<b>Contact Person:</b> <u>Elaine MacLachlan</u>	<b>LSL Project #:</b> <u>Lead testi.</u>
<b>Address:</b> <u>45 E. Elizabeth St.</u>	<b>Fax #:</b> <u>(315) 685-0347</u>		<b>Client's Site I.D.:</b>
<u>Skaneateles, NY 13152</u>		<b>Authorization:</b> <u>(315) 291-2297 Office</u>	<b>Client's Project I.D.:</b> <u>01 MEGA Sample ID</u>

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
	29 WM 13	12/2/20	7:21	X		PW	None	1	250 mL	SCSD-29 Lead		
	30 WM 8		7:21	X				1		30		
	31 WM 12		7:23	X				1		31		
	32 WM 9		7:23	X				1		32		
	33 WM 11		7:23	X				1		33		
	34 WM 10		7:23	X				1		34		
	35 WM 29		7:25	X				1		35		
	36 WM 29B		7:25	X				1		36		
	37 WM CO2BF		7:29	X				1		37		
	38 WM CS1A		7:30	X				1		38		
	39 WM 47		7:32	X				1		39		
	40			X				1				
				X				1				
				X				1				

<p><b>Notes and Hazard Identifications:</b></p> <p style="text-align: right; font-weight: bold;">Samples Preserved Upon Receipt at Lab</p>	<b>Custody Transfers</b>		<b>Date</b>	<b>Time</b>	
	<b>Sampled and Relinquished By:</b>				
	<b>Print Name:</b>		<b>Signature:</b>		
	<b>Received By:</b>				
	<b>Relinquished By:</b> <u>James Bond</u>		<b>Received By:</b>		12/3/20 1310
<b>Relinquished By:</b>		<b>Received for Lab By:</b>		12/3/20 1310	
<b>Shipment Method:</b>					